



कार्यालय नगर निगम कोटा दक्षिण (राज०)



क्रमांक :- जन स्वा./ननिको(द.)/2024/1143

दिनांक :- 20/12/2024

-:: प्रमाण-पत्र ::-

प्रमाणित किया जाता है कि स्प्रिंगडेल्स चिल्ड्रन स्कूल, नयागाँव, रावतभाटा रोड़, कोटा में स्थित है। उक्त विद्यालय का वातावरण स्वच्छ एवं साफ है तथा सफाई की अनुकूल व्यवस्था है। यह प्रमाण पत्र एक वर्ष के लिये मान्य होगा।

20/12/2024

स्वास्थ्य अधिकारी
स्वास्थ्य अधिकारी
नगर निगम कोटा, दक्षिण

PRINCIPAL
Springdales Children's School
Nayagaon, Kota



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : 246

Dated : 27/5/25

Issued to:

Principal

Springdales Children's School Nayagaon
Kota

District: Kota

Block/City: -

Sample No: Collected by Lab

Ref ID	53	Sample Code No.		PC-29 PB-23	
Reference : Letter No.		SCS/KOTA/1088		Source : RO	
Reference Date:		19.05.25	Source Location :	School Campus	
Date of Receipt :		19.05.25	Habitation/Ward No. :	-	
Sample ID	65				
Name of Sample Collector:		Dhanraj Ji	Village/Colony/Nagar :	-	
Designation of Sample Collector:		-	Gram Panchayat/City Area :	-	
Latitude of Location		Date of Collection :		19.05.25	
Longitude of Location		Start Date of Examination :		19.05.25	
Elevation of Location		End Date of Examination :		23.05.25	
Test Parameters		IS-10500:2012(RA 2018)		Sample Report No.	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	
Test Values					
1	pH At Temp. 25 ⁰ C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	7.66
2	Turbidity	1.0	5.0	-	0.66
3	Taste	Not Defined	Not Defined	-	-
4	Odour	Unobjectionable	Unobjectionable	-	-
5	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 1986 (RA2019)	70
6	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2019)	80
7	Calcium (as Ca ⁺⁺) mg/l	75	200	[IS 3025, P-40], 1991 (RA 2019)	-
8	Magnesium (as Mg ⁺⁺) mg/l	30	100	[IS 3025, P-46], 1994 (RA 2019)	-
9	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32],1988 (RA 2019)	30
10	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2022	2
11	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2019)	0.0281
12	Total Dissolved Solids (TDS) mg/l At 180 ⁰ C	500	2000	[IS 3025 P-16/APHA, Ed24, 2510-B] Cond 2022	149
11	Total Coliform (MPN/100ml)	Nil	Nil		240

(*ADL= Above detection limit; BDL= Below detection limit)

REPORT IS NOT VALID FOR
JUDICIAL AND COMMERCIAL
PURPOSE

Authorized Signatory
Principal
Springdales Children's School
Nayagaon, Kota
Senior Chemist
PHED Reg. Lab. Kota

NOTE:

- This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- This test report relates only to the samples/items submitted to the laboratory for test.
- This report is not valid for legal cases/legal purposes.
- Sample will be preserved only for 15 days from date of receipt.
- Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----

Public Health Engineering Department Regional Laboratory
AKELGARH KOTA -324010 (Raj.)
BACTERIOLOGICAL EXAMINATION OF WATER

PHED/Lab./Sr. Chemist/Bact./20.25.20...26 | 538

To,

The Springdale Children's School,
Kota.

Date : 12/8/25

Tehsil : Lalspura

District : Kota

Village : Kota

Code No. : U

Reference: Your letter no. 1102/30.7.25

Name of Sample Taker. Sh. Dharmraj Jangid

Sample Not Collected by Lead

[illegible]

REPORT IS NOT VALID FOR
JUDICIAL AND COMMERCIAL
PURPOSES.

PHED/Lab/Sr. Chemist/Bact/2025.....- 202.6.....

Date _____

Principal
Springdales Children's School
Navanagar
Senior Chemist
P.H.E.D. Regional Lab. Kota